



**MILBANK**  
ENERGY AT WORK

## U6123-X-BL



|                               |                                                                                       |
|-------------------------------|---------------------------------------------------------------------------------------|
| Catalog Number                | U6123-X-BL                                                                            |
| Marketing Product Description | 4 Terminal Ringless 3 Position Condo With House Panel Lever And Barrel Lock Provision |
| UPC                           | 784572668713                                                                          |
| Length (IN)                   | 5.969                                                                                 |
| Width (IN)                    | 36.5                                                                                  |
| Height (IN)                   | 30.5                                                                                  |
| Brand Name                    | Milbank                                                                               |
| Type                          | Ringless Meter Socket                                                                 |
| Application                   | Meter Socket With Main                                                                |
| Standard                      | UL Listed;Type 3R                                                                     |
| Voltage Rating                | Up to 240 Volts Alternating Current                                                   |
| Amperage Rating               | 125 Continuous Ampere                                                                 |
| Phase                         | 1 Phase                                                                               |
| Frequency Rating              | 60 Hertz                                                                              |
| Size                          | 5.969L x 36.5W x30.5H                                                                 |
| Number Of Cutouts             | 3                                                                                     |
| Cutout Size                   | Breaker Provision                                                                     |
| Cable Entry                   | Overhead or Underground                                                               |
| Terminal                      | Single Mechanical                                                                     |
| Insulation                    | Glass Polyester                                                                       |

|                           |                                                                      |
|---------------------------|----------------------------------------------------------------------|
| Mounting                  | Surface Mount                                                        |
| Enclosure                 | G90 Galvanized Steel with Powder Coat Finish                         |
| Jaw Quantity              | 4 Terminal                                                           |
| Bypass Type               | No Bypass on Residential Meter and Lever Bypass on Common Area Meter |
| Number of Meter Positions | 3 Positions                                                          |
| Equipment Ground          | Ground Lug                                                           |
| Hub Opening               | Large Closing Plate                                                  |
| Line Side Wire Range      | 6 AWG - 350 kcmil                                                    |
| Load Side Wire Range      | 1 AWG - 300 kcmil                                                    |
| Barrel Lock Provision     | 9/16 Inch Knockout and Angle Bracket for Barrel Lock Provision       |
| Number Of Receptacles     | 0                                                                    |

Please consult serving utility for their requirements prior to ordering or installing, as specifications and approvals vary by utility and may require local electrical inspector approval. All installations must be installed by a licensed electrician and must comply with all national and local codes, laws and regulations. Milbank reserves the right to make changes in specifications and features shown without notice or obligation.