


# Telescoping Strut Replacement, No Nut – TSR1220N



- Can be attached directly to a wall for wall-mounted applications
- Telescopes to the desired length and is locked in place by snapping closed a spring retainer clip
- Standard strut profile runs the entire length of the part, allowing most standard fittings to be placed anywhere between the rods
- Integrated ruler displays space between hanger rods in inches and centimeters
- Supports up to six 2" (50 DN) conduits, six 2" (50 DN) water filled pipes at 10' (3 m) spacing, or up to 18" (450 mm) cable tray
- Conduit can be supported on the top and bottom, eliminating the need for double sided strut
- Conduit and pipe can be placed directly on the strut profile, saving vertical space in buildings with limited room for installation



|                             |               |
|-----------------------------|---------------|
| Part Number                 | TSR1220N      |
| Material                    | Steel         |
| Finish                      | Pregalvanized |
| Rod Size (RS)               | 1/2"          |
| Hole Size (HS)              | 3/16"         |
| Thickness (T)               | 0.04"         |
| A                           | 12 1/2" – 20" |
| B                           | 14" – 21 1/2" |
| C                           | 1 5/8"        |
| D                           | 7/8"          |
| E                           | 1 3/8"        |
| Static Load 1 (F1)          | 300 lb        |
| Static Load 2 (F2)          | 200 lb        |
| Standard Packaging Quantity | 25 pc         |
| UPC                         | 78285691645   |
| EAN-13                      | 0782856916451 |

Static Load 1 represents a distributed load for 12" – 20" (300 – 500 mm) installations and a point load for 12" – 16" (300 – 400 mm) installations. Static Load 2 represents a point load for 16" – 20" (400 – 500 mm) installations.

## WARNING

Pentair products shall be installed and used only as indicated in Pentair's product instruction sheets and training materials. Instruction sheets are available at [erico.pentair.com](http://erico.pentair.com) and from your Pentair customer service representative. Improper installation, misuse, misapplication or other failure to completely follow Pentair's instructions and warnings may cause product malfunction, property damage, serious bodily injury and death and/or void your warranty.

© 2017 Pentair. All rights reserved.

Pentair, CADDY, CADWELD, CRITEC, ERICO, ERIFLEX, ERITECH and LENTON are owned by Pentair or its global affiliates.

All other trademarks are the property of their respective owners. Pentair reserves the right to change specifications without prior notice.

