



Catalog Number: 4418-GSC1
Item Description: N1 SCREW CVR GUTTER
UPC Code: 784572106352



Brand Name: Milbank
Type: Lay In Wireway
Application: Wireway
Standard: UL Listed, Type 1
Cover Type: Screw Cover
Enclosure: Indoor Enclosure
Nominal Cross Section: 4x4
Straight Section Length: 18
Material: Steel with Powder Coat Finish
Finish: ANSI 61 Gray
Knockouts: True



Utility requirements may vary. Always consult the serving utility for their requirements prior to ordering or installing this equipment. This product must always be installed by a licensed electrician. Installation of this equipment may require local electrical inspector approval.


PREFIX	LABEL NO.
NONE	1002943
RC-	1125051

ITEM	QTY.	PART NUMBER	DESCRIPTION
1	1	(SEE CHART)	BACK
2	1	(SEE CHART)	PLATE/COVER
3	1	(SEE CHART)	UL LABEL, WIREWAY
4	1	1002900	LABEL, WIREWAY FITTING
5	4	1001290	SCREW, 10-32 X 5/16
6	2	1002880	BAG ASSY (NOT SHOWN)



NOTE:
1. PLACE BAG ASS'Y INSIDE ENCLOSURE. (NOT SHOWN)


SUFFIX	BACK #	COVER #
-SU	1010663	1011799
-SUC	1128849	1128832
-SO	1128850	1104931
-SUNK	1128851	1011799
-NK	1111211	1104931
-SUNKC	1128852	1128832



SUFFIX	FINISH
NONE	PAINTED
-NP	NOT PAINTED

NEMA DWG.: #236

B	05/16/02	REVISED PER - PMR 2444	DY	C	8-28-07	ADDED BACK & COVER CHART ECO. 15946	DL	Scale:	NTS	Checked By:		Drawing No.:	1011109
B1	8-22-06	mECO #15092, ADDED NOTE #2.	CMW	D	12/20/12	1002880 (2) WAS (3) (ECO #23330)	D.F.	Drawn By:	DY	Approved By:		Date:	05/16/02

Material:	16 GA. - SEE CHART	 General Offices: Kansas City, MO	
Finish:	SEE CHART		
Tolerances: Unless Specified Otherwise X.X ±.1 X.XX ±.03 X.XXX ±.015 X" ±2"		Third Angle  Projection	
Title:		SCREW COVER WIREWAY 4 x 4 x 18, TYPE 1 NEMA ENCLOSURE	
Catalog No.:		4418-GSC1	
Customer:		MILBANK STANDARD	
Date:		05/16/02	
Sheet		1 of 1	