Catalog Number:	6660-GSC1
Item Description:	N1 SCREW CVR GUTTER
UPC Code:	784572108240


Brand Name:	Milbank
Type:	Lay In Wireway
Application:	Wireway
Standard:	UL Listed, Type 1
Cover Type:	Screw Cover
Enclosure:	Indoor Enclosure
Nominal Cross Section:	6x6
Straight Section Length:	60
Material:	Steel with Powder Coat Finish
Finish:	ANSI 61 Gray
Knockouts:	True




Utility requirements may vary. Always consult the serving utility for their requirements prior to ordering or installing this equipment. This product must always be installed by a licensed electrician. Installation of this equipment may require local electrical inspector approval.


CATALOG#	LABEL#
6660-GSC1-( )	1002943
RC-6660-GSC1-( )	1125051
SPS-665( )	1132575

NO	QTY.	PART NO.	DESCRIPTION
1	1	(SEE CHART)	BACK
2	1	(SEE CHART)	PLATE/COVER
3	1	(SEE CHART)	UL LABEL, WIREWAY
4	1	1002942	LABEL, RATING
5	4	1001290	SCREW, 10-32 X 5/16
6	3	1002880	BAG ASSY (NOT SHOWN)



SUFFIX	BACK #	COVER #
-SU	1001357	1003281
-SUC	1128948	1128931
-SO	1128949	1011779
-SUNK	1010575	1003281
-NK	1099499	1011779
-SUNKC	1128950	1128931





SUFFIX	FINISH
NONE	MILBANK LIGHT GRAY
-NP	NONE

NOTE:
1. PLACE BAG ASS'Y INSIDE ENCLOSURE. (NOT SHOWN)

NEMA DWG.: #252

D	8-28-07	ADDED BACK & COVER CHART ECO. 15946	DL	D2	3/19/13	RENAME DRAWING (ECO #23663)	D.F.
D1	5/7/08	ADDED CHART & REMOVED NOTE #2(ECO.17139)	JLT				

Material:	16 GA. - SEE CHART		
Finish:	SEE CHART		
Tolerances: Unless Specified Otherwise: X.X ±.1, X.XX ±.03, X.XXX ±.015, X° ±2°		Third Angle Projection	
Scale:	NTS	Checked By:	
Drawn By:	DY	Approved By:	

MILBANK MANUFACTURING CO. General Offices: Kansas City, MO

Title:	SCREW COVER WIREWAY 6 x 6 x 60, TYPE 1 NEMA ENCLOSURE
Catalog No.:	(SEE CHART)
Customer:	MILBANK STANDARD
Drawing No.:	1003058
Date:	05/24/02 Sheet 1 of 1