




Catalog Number: 8818-GSC1
Item Description: N1 SCREW CVR GUTTER
UPC Code: 784572109223

Brand Name: Milbank
Type: Lay In Wireway
Application: Wireway
Standard: UL Listed, Type 1
Cover Type: Screw Cover
Enclosure: Indoor Enclosure
Nominal Cross Section: 8x8
Straight Section Length: 18
Material: Steel with Powder Coat Finish
Finish: ANSI 61 Gray
Knockouts: True




Utility requirements may vary. Always consult the serving utility for their requirements prior to ordering or installing this equipment. This product must always be installed by a licensed electrician. Installation of this equipment may require local electrical inspector approval.

PREFIX	LABEL NO.
NONE	1002943
RC-	1125051




NO.	QTY.	PART NO.	DESCRIPTION
1	1	(SEE CHART)	BACK
2	1	(SEE CHART)	PLATE/COVER
3	1	(SEE CHART)	UL LABEL, WIREWAY
4	1	1002913	LABEL, RATING
5	4	1001290	SCREW, 10-32 X 5/16
6	2	1002880	BAG ASSY (NOT SHOWN)

SUFFIX	MATERIAL	BACK #	COVER #
-SU	CRS	1130387	1097034
-SUC	CRS	1129069	1129033
-SO	GALV	1129070	1129034
-SUNK	CRS	1097033	1097034
-NK	GALV	1129071	1129034
-SUNKC	CRS	1129072	1129033



SUFFIX	FINISH
NONE	PAINTED
-NP	NOT PAINTED

Material:	16 GA. - SEE CHART	 MILBANK MANUFACTURING CO. General Offices: Kansas City, MO	
Finish:	SEE CHART	Title:	SCREW COVER WIREWAY 8 x 8 x 18, TYPE 1 NEMA ENCLOSURE
Tolerances: Unless Specified Otherwise X.X ±.1 X.XX ±.03 X.XXX ±.015 X" ±2" Third Angle  Projection		Catalog No.:	8818-GSC1
		Customer:	MILBANK STANDARD
Scale:		Drawing No.:	1000760
Drawn By:	DY	Date:	08/19/02
Checked By:		Sheet	1 of 1

E	11/04/2014	CHANGED MATERIAL (eECR0030014)	AJS	C	8-29-07	ADDED BACK & COVER CHART ECO. 15946	DL
B1	9-18-06	mECO #15183, ADDED NOTE #2.	CMW	D	9/9/11	1002880 (2) WAS (4) (ECO #21290)	D.F.