



Catalog Number: 8812-GSC1-NK-NP
Item Description: N1 SCREW CVR GUTTER NK NP
UPC Code: 784572155015


Brand Name: Milbank
Type: Lay In Wireway
Application: Wireway
Standard: UL Listed, Type 1
Cover Type: Screw Cover
Enclosure: Indoor Enclosure
Nominal Cross Section: 8x8
Straight Section Length: 12
Material: G90 Galvanized Steel
Finish: Unpainted
Knockouts: False




Utility requirements may vary. Always consult the serving utility for their requirements prior to ordering or installing this equipment. This product must always be installed by a licensed electrician. Installation of this equipment may require local electrical inspector approval.

CATALOG#	LABEL#
8812-GSC1-()	1002943
RC-8812-GSC1-()	1125051
SPS-881()	1132575

NO.	QTY.	PART NO.	DESCRIPTION
1	1	(SEE CHART)	BACK
2	1	(SEE CHART)	PLATE/COVER
3	1	(SEE CHART)	UL LABEL, WIREWAY
4	1	1002913	LABEL, RATING
5	4	1001290	SCREW, 10-32 X 5/16
6	2	1002880	BAG ASSY (NOT SHOWN)




SUFFIX	MATERIAL	BACK #	COVER #
-SU	CRS	1010690	1012195
-SUC	CRS	1129064	1105531
-SO	GALV	1129065	1101404
-SUNK	CRS	1010692	1012195
-NK	GALV	1101405	1101404
-SUNKC	GALV	1105484	1105531



SUFFIX	FINISH
NONE	PAINTED
-NP	NOT PAINTED

NOTE:
1. PLACE BAG ASS'Y INSIDE ENCLOSURE. (NOT SHOWN)

Material:	16 GA. - SEE CHART	 General Offices: Kansas City, MO	
Finish:	SEE CHART	Title:	SCREW COVER WIREWAY 8 x 8 x 12, TYPE 1 NEMA ENCLOSURE
Tolerances: Unless Specified Otherwise X.X ±.1 X.XX ±.03 X.XXX ±.015 X" ±2" Third Angle  Projection		Catalog No.:	(SEE CHART)
		Customer:	MILBANK STANDARD
Scale:	NTS	Drawing No.:	1003693
Drawn By:	DY	Date:	08/19/02
Checked By:		Sheet	1 of 1
Approved By:			

E	11/04/2014	CHANGED MATERIAL (eECR0030014)	AJS	C1	5/7/08	ADDED CHART & REMOVED NOTE#2 (ECO#17139)	JLT
C	8-29-07	ADDED BACK & COVER CHART ECO. 15946	DL	D	6/22/11	1002880 (2) WAS (4) (ECO #20877)	D.F.