




Catalog Number:
Item Description:
UPC Code:

TB200-47
200A RPLCMNT TEST BLOCK
784572171169

Brand Name: Milbank
Type: Test Block
Application: Replacement Part
Number Of Terminals: 2
Wire Size: 1/0 AWG to 250 kcmil
Amperage Rating: 200 Ampere
Voltage Rating: 600 Volts Alternating Current
Mounting: Surface Mount
Connection: Mechanical Lugs



Utility requirements may vary. Always consult the serving utility for their requirements prior to ordering or installing this equipment. This product must always be installed by a licensed electrician. Installation of this equipment may require local electrical inspector approval.