



Catalog Number: 6696-GSC1
Item Description: N1 SCREW CVR GUTTER
UPC Code: 784572276109

Brand Name: Milbank
Type: Lay In Wireway
Application: Wireway
Standard: UL Listed, Type 1
Cover Type: Screw Cover
Enclosure: Indoor Enclosure
Nominal Cross Section: 6x6
Straight Section Length: 96
Material: Steel with Powder Coat Finish
Finish: ANSI 61 Gray
Knockouts: True






Utility requirements may vary. Always consult the serving utility for their requirements prior to ordering or installing this equipment. This product must always be installed by a licensed electrician. Installation of this equipment may require local electrical inspector approval.

CAT NO.	U/L LABEL
6696-GSC1-()	1002943
RC-6696-GSC1-()	1125051

SUFFIX	FINISH
NONE	PAINTED
-NP	NOT PAINTED


SUFFIX	BACK #	COVER #
-SU	1105116	1003286
-SUC	1128964	1128932
-SO	1128965	1011821
-SUNK	1105125	1003286
-NK	1105134	1011821
-SUNKC	1128966	1128932

ITEM	QTY.	PART NUMBER	DESCRIPTION
1	1	(SEE CHART)	BACK
2	2	(SEE CHART)	PLATE/COVER
3	1	(SEE CHART)	UL LABEL, WIREWAY
4	1	1002942	LABEL, RATING
5	8	1001290	SCREW, 10-32 X 5/16
6	4	1002880	BAG ASSY (NOT SHOWN)



NOTE:
1. PLACE BAG ASSY INSIDE ENCLOSURE. (NOT SHOWN)

NEMA NO.: #11453

Material:		16 GA. - SEE CHART				
Shear/ Die#:						
Finish:		SEE CHART				
Part Wt.:				General Offices:	Kansas City, MO	
				Title:	SCREW COVER WIREWAY 6 x 6 x 96, TYPE 1 NEMA ENCLOSURE	
Tolerances: Unless Specified Otherwise X.X ±.1 X.XX ±.03 X.XXX ±.015 X" ±2"				Third Angle 		
Catalog No.:		(SEE CHART)				
Customer:		MILBANK STANDARD				
Drawing No.:		1008732				
Scale:		NTS		Checked By:		
Drawn By:		DY		Approved By:		
Date:		05/23/02		Sheet	1 of 1	

REV.	DATE	DESCRIPTION	BY
A	5-29-07	ADDED BACK & COVER CHART & REMOVED IT. 1105133 & ADDED IT. 1011821 & IT. 1001290 ECO. 15946	DL
A1	3-19-13	CHARTED UL LABEL; DWG. NUMBER WAS 11453 (ECO #23665)	DL
B	2-11-14	CHGD QTY LINE 5 TO 8PCS eECR2703	AJS