# PHILIPS Day-Brite *CFI*

## Recessed

T-Grid LED troffer 2x2

2000, 3000, 3800 or 4500 lumens



Project:	
Location:	
Cat.No:	
Туре:	
Lamps:	Qty:
Notes:	

The Philips Day-Brite / Philips CFI T-Grid LED troffer is an energy efficient low profile luminaire offering excellent performance for general lighting applications such as offices, schools, healthcare, or retail. Featuring a frosted prismatic lens to enhance visual comfort, the T-Grid LED Troffer utilizes highly reliable and efficient Philips LED platform boards and dimmable driver, enabling market leading efficiency in its category.

### Ordering guide

### Example: 2TG30L840-2-FS-02F-UNV-DIM

Width	Family	Ceiling Type	Lumen Package	Color Temp.	Length	Door Frame	Lens	Voltage	Driver	Options
2	Т	G		-	2 –	-	-	-	-	
2 2'	T T-Grid LED troffer	G Grid	<ul> <li>20L 2000 nominal delivered lumens</li> <li>30L 3000 nominal delivered lumens</li> <li>38L 3800 nominal delivered lumens</li> <li>45L 4500 nominal delivered lumens</li> </ul>	830 80 CRI, 3000K 835 80 CRI, 3500K 840 80 CRI, 4000K 850 80 CRI, 5000K	2 2'	FS Flat Steel FA Flat Aluminum RA Regressed Aluminum	02F Pattern 12, 100" nominal diffuse 50% 12F DB 12.125" nominal diffuse 50% 19F DB 19.156" nominal diffuse 50%	UNV Universal Voltage 120-277V 347 347V	DIM 0-10V dimming SDIM Step to 40% input power	F1       3/8" flex, 3 wire, 18 gauge 6'         F2       3/8" flex, 4 wire, 18 gauge 6'         F1/D       3/8" twin flex, 3 wire, 18 gauge 6', for dimmable luminaires         F2/5W       3/8" single flex, 5 wire, 18 gauge 6', for dimmable luminaires         F2/5W       3/8" auge 6', for dimmable luminaires         INEgral emergency battery pack         IW       1-way gasket between lens & door frame (not avail. for RA door frame)         2W       1-way & gasket between housing & ceiling (field installed)         3W       2-way & gasket between housing & ceiling (field installed)         GLR       Fusing, fast blow CHIC

### **Footnotes**

1 Emergency pack mounted in enclosure on top of fixture housing. Delivers 1100 nominal lumens in DC mode.

### Accessories (order separately)

- FMA22 2'x2' "F" mounting frame for NEMA "F" mounting
- FKTG822 Flange conversion kit, 2'x2'



# **2TG** T-Grid LED troffer 2x2

### 2000, 3000, 3800 or 4500 lumens

### Application

- High efficacy long life solid state lighting platform.
- · General lighting distribution is excellent for ambient lighting.
- · High CRI source provides excellent color rendering
- · LEDs are an excellent source for use with controls since frequent switching does not affect the life of the light source.

### **Construction/finish**

- · A quality low-profile troffer with specification features for NEMA "G" grid, NEMA "NFG" narrow face grid, NEMA "GR" grid regressed, or NEMA "F" flange ceiling types.
- 3" nominal housing depth, 3-3/16" maximum depth.
- Smooth rolled edges on all four sides for easy handling
- · Die-formed one piece housing includes stiffening embosses and provides increased rigidity
- · Housing is multi-stage phosphate treated for maximum corrosion resistance and finish coat is high reflectance baked white enamel.
- Integral baffling system to prevent light leaks.
- · 2 sets of integral grid clips (wraparound and fold-out) for maximum mounting flexibility.

- · Integral wire hanger holes for independent wire suspension.
- Embosses with holes provided in housing end for screwing to T-bar if desired
- 7/8" K.O.'s provided in each end cap for through wiring
- Factory installed access plate in housing top includes 7/8" hole with rolled edge and 7/8"
- · Carton includes integral carrying handle for easy handling.

### Electrical

- Standard 0–10V dimming.
- Driver and LED boards are accessible from below. LED boards are individually replaceable if required
- · Five-year luminaire limited warranty including LED boards and driver. Visit www.philips. com/warranties for complete warranty information
- High efficiency LEDs have 50,000 hour rated life (defined by testing at 70% lumen maintenance (L70)), based on 25°C ambient operating temperature.
- · cETLus listed to UL and CSA standards, suitable for damp location.
- T-Grid LED luminaires are DesignLights Consortium® qualified. Please see the DLC QPL list for exact catalog numbers (http://www. designlights.org/QPL).

 Many luminaire components, such as reflectors, refractors, lenses, sockets, lampholders, and LEDs are made from various types of plastics which can be adversely affected by airborne contaminants. If sulfur based chemicals, petroleum based products, cleaning solutions, or other contaminants are expected in the intended area of use, consult factory for compatibility.


### Enclosure

- Full "C" channel door frames for improved lens support and reduced shipping damage.
- Flat steel door frame features smooth rolled edges inside and outside.
- All door frames have mitered corners.
- All door frames use T-hinges and can be hinged and latched from either side
- · Opposable spring loaded latches are standard for easy operation and consistent retention

### **Dimensions**



\*EMLED option adds 1-3/4" to overall height



Fold-Out Grid Clips

# **2TG** T-Grid LED troffer 2x2

### 2000, 3000, 3800 or 4500 lumens

### Photometry

### 2x2 T-Grid LED troffer, 2000 nominal delivered lumens

2x2 T-Grid LE	D troffer, 2000 nominal d	elivered l	umens		LE	R – 99										
		Candlepower				Light Distribution					Average Luminance					
Catalog No.	atalog No. 2TG20L840-2-FS-02F-UNV		Angle End		Cross	Degr	rees Lumens		ens % Luminaire		ire Angle	End	45°	Cross		
Test No.	32630	0	983	<b>45</b> 983	983	0-30		747	32.7		45	2442	2472	2551		
S/MH	1.2	5 15	978 933	978 935	979 937	0-40		1191 1915	52.1 83.7	,	55 65		1977 1518	2058 1644		
Source	LED	25	844	849	856	0-90		2287	100.0		75	1427	1384	1618		
Lumens/Lamp	2287	<b>35</b> 45	703 526	709 532	709 549	C (1		<i></i>			85	1570	1597	1831		
Input Watts	23	55	344	345	359	Coeff	icients	of Uti	lization							
		65								NCE 20 P	0 PER (pfc=0.20)					
		75	112	109	127	рсс		80			70		5	0		
	ly lighting energy cost per	85	42	42	49	pw	70	50	30	70	50	30	50	30		
· · · · · · ·	.42 based on 3000 hrs. and					RCR	110	118	118	115	115	115	111	111		
\$.08 pwr KWH. Ac	tual rates and usage may vary.					1	118 109	105	101	107	103	98	111 97	111 94		
The substant states						2	100	93	85	97	91	84	86	81		
	esults were obtained in the					3	92	81	75	90	81	73	78	71		
	aboratory which is NVLAP					4	84	72	65	82	71	64	69	63		
,	National Institute of Standards					5	78	66	57	76	65	56	63	56		
and Technology.						6	72	59	51	70	58	51	56	50		
						7	68	55	46	66	54	46	52	45		
	es based on test performed in					8	63	50	41	61	48	41	47	40		
compliance with L	M-79.					9	58	46	38	57	46	38	44	38		

LER – 92

  Т

#### 2x2 T-Grid LED troffer, 3000 nominal delivered lumens

#### Candlepower **Light Distribution** Average Luminance Catalog No. 2TG30L840-2-FS-02F-UNV Fnd Degrees 0-30 Fnd 45° Angle Cross Lumens % Luminaire Angle 45 **Cross** 3342 Test No. 32.7 0-40 0-60 65 52.0 S/MH 1.2 15 1223 1228 LED 0-90 100.0 Source 35 45 55 65 75 85 689 696 719 Lumens/Lamp **Coefficients of Utilization** Input Watts 32.7 277 167 EFFECTIVE FLOOR CAVITY REFLECTANCE 20 PER (pfc=0.20) 147 142 pcc pw RCR Comparative yearly lighting energy cost per 1000 lumens - \$2.61 based on 3000 hrs. and \$.08 pwr KWH. Actual rates and usage may vary. 100 71 The photometric results were obtained in the 72 Philips Day-Brite laboratory which is NVLAP accredited by the National Institute of Standards 51 50 45 and Technology. 55 Photometric values based on test performed in 57 compliance with LM-79. 34

# **2TG** T-Grid LED troffer 2x2

### 2000, 3000, 3800 or 4500 lumens

### Photometry

### 2x2 T-Grid LED troffer, 3800 nominal delivered lumens

		Candlepower					Distril	oution		Average Luminance					
Catalog No.	2TG38L840-2-FS-02F-UNV	Angle	End	45	Cross	Degr	ees	Lumens	% Lumi	naire	Angle	e End	45°	Cross	
Test No.	32631	0	1586	1586	1586	0-30		1206	32.7		45		3990	4130	
S/MH	1.2	5	1578	1578	1580	0-40		1922	52.0		55		3193	3330	
Source	LED	15 25	1505 1362	1509 1369	1514 1384	0-60 0-90			83.7 100.0		65 75	2301	2456 2219	2660 2625	
Lumens/Lamp	3693	35	1136	1143	1169						85	2545	2588	2951	
Input Watts	43.5	45 55	848 555	859 557	889 581	Coeff	icients	of Uti	lization						
input matts	13.5	65 326 316 342 EFFECTIVE FLOOR CAVITY REFLECTANCE								ANCE 20 P	20 PER (pfc=0.20)				
		75	181	175	207	рсс		80			70		5	0	
	y lighting energy cost per	85	68	69	78	pw	70	50	30	70	50	30	50	30	
	82 based on 3000 hrs. and					RCR									
\$.08 pwr KWH. Act	ual rates and usage may vary.					0	118	118	118	115	115	115	111	111	
						1	109	105	101	107	103	98	97	94	
The photometric re	esults were obtained in the					2	100	93	85	97	91	84	86	81	
Philips Day-Brite la	aboratory which is NVLAP			1		3	92	81	75	90	81	73	78	71	
	National Institute of Standards					4	84	72	65	82	71	64	69	63	
and Technology.						5	78	66	57	76	65	56	63	56	
and rechnology.						6	72	59	51	70	58	51	56	50	
DI 1 1 1						/	68	55	46	66	54	46	52	45	
	s based on test performed in					8	63	50	41	61	48	41	47	40	
compliance with LI	M-79.					<u>9</u> 10	58 55	46	38 34	57 54	46 41	38 34	44	38 34	

#### 2x2 T-Grid LED troffer, 4500 nominal delivered lumens

		Candlepower				Light Distribution					Average Luminance				
Catalog No.	2TG45L840-2-FS-02F-UNV	Angle	End	45	Cross	Degr	ees	Lumens	% Lumir	naire	Angl	e End	45°	Cross	
Test No.	32395	0	1968	1968	1968	0-30		1489	32.7	7	45	4852	4887	5031	
S/MH	1.2	5	1958	1957	1960	0-40		2366	52.0 83.6		55		3952	4127	
Source	LED	15 25	1864 1677	1867 1687	1873 1702	0-60		3805 4550	100.0		75		3111 2789	3327 3167	
Lumens/Lamp	4551	35	1392	1401	1428						85	3038	3066	3468	
Input Watts	51.5	45	1044	1052	1083	Coeff	icients	of Uti	lization						
Input watts	51.5	55 65	55         691         690         720           65         412         400         428         EFFECTIVE FLOOR CAVITY REFLECTANCE 20							NCF 20 P	FR (nfc:	0 20)			
	75	226	220		pcc		80			70	0.207	5	С		
	y lighting energy cost per	85	81	81	92	pw	70	50	30	70	50	30	50	30	
	79 based on 3000 hrs. and					RCR	110	110	110	110	110	11.0	111	111	
3.08 pwr KWH. Aci	ual rates and usage may vary.					0	119 109	119 105	119 101	116 107	116 103	116 99	111 98	111 95	
The photometric w	culto ware obtained in the					2	109	93	86	98	91	85	87	82	
	esults were obtained in the aboratory which is NVLAP					3	92	82	74	90	81	74	78	72	
						4	85	73	65	83	72	64	70	63	
,	National Institute of Standards					5	78	66	58	76	65	57	63	56	
and Technology.						6	73	60	51	71	59	51	57	50	
<b>D</b> I I I I I						7	68	55	46	66	54	46	52	45	
	s based on test performed in					8	63	50	42	62	49	42	48	41	
compliance with L	M-79.					9 10	59 55	46 43	38 35	58 54	46	38 35	44	38 34	

© 2016 Philips Lighting Holding B.V. All rights reserved. Philips reserves the right-make changes in specifications and/or-discontinue any product at any time without notice or obligation and will not be liable for any consequences resulting from the use of this publication. philips.com/luminaires



Philips Lighting North America Corporation 200 Franklin Square Drive, Somerset, NJ 08873 Tel. 855-486-2216

Philips Lighting Canada Ltd. 281 Hillmount Rd, Markham, ON, Canada L6C 2S3 Tel. 800-668-9008

TGrid\_LED\_2x2 03/16 page 4 of 4

#### LER – 88

LER - 85